

22/04/2021

OZFLOW  
PO BOX 1571  
SUNNYBANK HILLS  
4109 QLD

Dear Gavin Heitman

**PRODUCT APPROVAL – OzFlow stainless steel floor drains**

I refer to your application for authorisation of the OzFlow stainless steel floor drains of various model numbers.

South Australian Water Corporation approves the installation of the OzFlow stainless steel floor drains (model numbers listed below) for connection to SA Water's Sewerage System for a period of 5 years commencing from the date of this letter, subject to the following conditions. A further review will be conducted towards the end of the approval period.

Products approved under this authorisation:

- A-DRS-100-ES
- A-DRS-150-RD-S
- A-SF-218-2
- A-SFD-283-2
- A-SBS-200-2
- A-SRS-150-ES
- A-75-400-150-E-S
- A-SFD-218-2
- A-SBS-110-2
- A-DRS-100-RD-S
- A-75-600-200-E-S
- A-SF-283-2
- A-SBS-160-2

Conditions of approval

1. SA Water accepts no responsibility for and does not vouch for the efficiency or performance of the product. This approval letter is not an endorsement of the product by the SA Water Corporation, and no claim shall be made through advertising, promotion or any other way.
2. The product shall be suitable for the designed application and intended environment, internally and externally for the stated life expectancy of the device.
3. Primary and fixed secondary screens must not have a hole size/aperture/perforation greater than 3 mm in diameter (or at the widest point).
4. The models shall be manufactured in accordance with the drawings submitted with the application and be supplied to the purchaser with installation instructions and procedures for maintenance and care.
5. Variation to the conditions of this approval may be necessary due to circumstances beyond the Corporation's control, such as changes in law. Where practicable to do so, the Corporation will give reasonable advanced notice in writing of such variation.
6. SA Water has assessed this product in principle for the use in a trade waste pre-treatment system. It has not assessed any other legislative requirements (i.e. plumbing standards).

7. SA Water may inspect the OzFlow stainless steel floor drain systems installed in customer's sites. If, in the opinion of SA Water, defects or customer complaints are significant, the authorisation of the OzFlow stainless steel floor drains as trade waste pre-treatment may be suspended or cancelled.
8. This approval applies to model specifications of the product as at the date of this letter. Any changes that may affect the durability or performance of the design shall be resubmitted to SA Water for evaluation.
9. This product approval may be revoked at any time if the conditions within are not adhered to.

Regards



Joe Gest  
**Technical Support Officer – Trade Waste**

Phone: 74241336  
Email: [tradewaste@sawater.com.au](mailto:tradewaste@sawater.com.au)